


REVIEWED
AUG 27 2018
Austin Water Utility
Rod Chon
Details below

A WATER FROM UCM 2.9.2.818 HAS BEEN GRANTED BY AWU
THIS SECTION REQUIRES THAT UTILITY CROSSINGS CONSTRUCTED UNDER CAST-IRON
WATER MAINS BY OPEN CUT METHODS BE REMOVED AND REPLACED WITH NEW
PIPE CURRENTLY APPROVED FOR USE IN THE AUSTIN WATER SYSTEM. ON THIS
PROJECT, THE EXISTING 6" CAST-IRON WATER MAIN WILL BE REMOVED AND
REPLACED IN ACCORDANCE WITH THE UCM. EXISTING 24" CAST-IRON
WATER MAIN SHALL BE EXEMPT FROM THIS REQUIREMENT.

- NOTES:
1. THIS PLAN APPROVED FOR UTILITY RELOCATION PURPOSES ONLY; NOT RELEASED FOR CONSTRUCTION. AUSTIN ENERGY WILL PROVIDE "ISSUE FOR CONSTRUCTION" PLANS FOR FINAL DRY UTILITY DUCT BANK AND SERVICES FOLLOWING RECEIPT OF AULGC APPROVAL.
 2. ONLY VISIBLE IMPROVEMENTS & UTILITIES WERE PROVIDED FROM SURVEY (THE SURVEYOR/ENGINEER HAS NOT PHYSICALLY LOCATED THE UNDERGROUND UTILITIES). LOCATIONS OF EXISTING UTILITIES, SOME OF WHICH MAY NOT BE SHOWN, COULD IMPACT CONSTRUCTION MEANS AND METHODS. CONTRACTOR TO VERIFY ALL EXISTING UTILITIES VERTICALLY AND HORIZONTALLY PRIOR TO BID & CONSTRUCTION, AND SHALL NOTIFY THE ENGINEER IMMEDIATELY OF ANY DISCREPANCIES. THE CONTRACTOR TO CONTACT THE AUSTIN AREA "ONE CALL" SYSTEM @ 811, OR THE OWNER OF EACH INDIVIDUAL UTILITY FOR ASSISTANCE IN DETERMINING EXISTING UTILITY LOCATIONS.
 3. THE SIZE AND LOCATION OF UTILITY STRUCTURES, (IF SHOWN), MAY BE EXAGGERATED FOR GRAPHICAL CLARITY. THE SURVEY SHOWS FIELD MEASURED SIZES AND DEPTHS AS OBSERVED FROM GROUND LEVEL OPENINGS.
 4. REFERENCE COA CASE #SP-2016-0196C UTILITY PLAN FOR ADDITIONAL INFORMATION.
 5. NO CONCRETE ALLOWED ABOVE CONDUITS TO FINISHED GRADE.

C2
ADDED SHEET



SITE PLAN APPROVAL Sheet 41 of 38
FILE NUMBER SP-2016-0196C APPLICATION DATE APRIL 22, 2016
APPROVED BY COMMISSION ON UNDER SECTION 112 OF
CHAPTER 25-5 OF THE CITY OF AUSTIN CODE
EXPIRATION DATE (SP-2016-0196C) CASE MANAGER SCOTT GRANTHAM
PROJECT EXPIRATION DATE (SP-2016-0196C) DWG 202
Planning and Development Review Department
RELEASED FOR GENERAL COMPLIANCE: ZONING 2011-218
Rev. 1 Correction
Rev. 2 Correction 2
Rev. 3 Correction 3
Final plot must be recorded by the Project Expiration Date, if applicable.
Subsequent Site Plans which do not comply with the Code current at the time of filing, and all required Building Permits and/or a notice of construction (if a building permit is not required), must also be approved prior to the Project Expiration Date.

512.669.5560
www.bigreddog.com
TEXAS REG. NO. 17-11201
BIG RED DOG
ENGINEERING / CONSULTING
2021 E. 9TH ST. #200 (OFFICE) • 815-A BRAZOS ST. #319 (MAIL)
AUSTIN, TEXAS 78702 (OFFICE), 78701 (MAIL)
03.26.18
STATE OF TEXAS
RICARDO M. DE CAMPOS
122378
LICENSED PROFESSIONAL ENGINEER
2010 SOUTH LAMAR OFFICE
2010 S. LAMAR
AUSTIN, TRAVIS COUNTY, TEXAS
UTILITY PLAN AND PROFILE PROP. 6 IN FH LEAD
SHEET
CU105
41 OF 41
SP-2016-0196C