



Design Flow Calculations:

Maximum Daily Flow = 288000.00 gals/day (peak)
= 960.00 gals/min (peak)

Wet Well Design Calculations:

Pump Capacity = 1250.00 gal/min.
Using Maximum Daily Inflow = 1000.00 gals/min (MDF)
1250.00 net outflow in gallons per minute

5' Dia. Well: 146.90 gals/foot of depth

det depth	det vol	flow	time	flow	time	flow	time
5.00	734.50	250.00	2.94	1000.00	0.73	1250.00	3.67

Total Dynamic Head Calculations:

Discharge Pipe: 10.00 Linear Feet
roughness, c = 130.00 Material: DI
diameter, d = 6.00 inches
flow, q (gpm) = 1250.00 (pumping capacity)

$$f = 0.21 \times (100/c)^{1.85} \times \frac{q^{1.85}}{d^{4.8655}}$$

f = 11.25 feet/100 ft of pipe
Total Friction Loss = 1.12 feet
Velocity, v = 14.18 fps (3 to 6 fps is an acceptable range)

Minor Losses in Discharge Pipe:
HL = $\frac{K \times V^2}{2g}$ where: K = 0.9 for 90 deg. bends
K = 0.5 for 45 deg. bends
K = 0.3 for 22.5 deg. bends
K = 2.5 for Swing Check Valve, open full
K = 0.2 for Gate Valve, open full

Number of 90 deg. bends =	2.00
Number of 45 deg. bends =	0.00
Number of 22.5 deg. bends =	0.00
Number of Swing CVs =	1.00
Number of Gate Valves =	1.00

Total Minor Losses = 14.06 feet

Force Main: 144.00 Linear Feet
roughness, c = 130.00 Material: C900 PVC
diameter, d = 8.00 inches
flow, q (gpm) = 2500.00 (pumping capacity)

$$f = 0.21 \times (100/c)^{1.85} \times \frac{q^{1.85}}{d^{4.8655}}$$

f = 10.00 feet/100 ft of pipe
Total Friction Loss = 14.40 feet
Velocity, v = 15.96 fps (3 to 6 fps is an acceptable range)

Minor Losses in Force Main:
HL = $\frac{K \times V^2}{2g}$ where: K = 0.9 for 90 deg. bends
K = 0.5 for 45 deg. bends
K = 0.3 for 22.5 deg. bends
K = 2.5 for Swing Check Valve, open full
K = 0.2 for Gate Valve, open full

Number of 90 deg. bends =	0.00
Number of 45 deg. bends =	2.00
Number of 22.5 deg. bends =	0.00
Number of Swing CVs =	0.00
Number of Gate Valves =	0.00

Total Minor Losses = 3.95 feet

Total Dynamic Head = Static Head + Line Pressure + Losses = 43.04

LOCATION OF ALL ANCHOR BOLTS, RELATIVE POSITION OF PUMPS AND ACCESS COVER, MUST BE MAINTAINED ACCORDING TO MANUFACTURER'S RECOMMENDATIONS.

NO.	DATE	REVISIONS	APPROVAL
2C	6/25/19	ADD PUMP STATION FOR DRAIN IN ACCESS DRIVE	

BOULDIN CREEK COMMONS
2043 S LAMAR BLVD, AUSTIN, TX 78704

PUMP STATION PLAN & SECTION

CIVILITUDE
ENGINEERS & PLANNERS

5110 LANCASTER COURT, AUSTIN, TX 78723 FIRM REG # F12469
PHONE 512 761 6161 FAX 512 761 6167 INFO@CIVILITUDE.COM

SCALE: AS SHOWN

JOB NO: A340

DGN BY: JMS

DWN BY: MAA

RVW BY: JMS



SITE PLAN APPROVAL SHEET 15 OF 31
FILE NUMBER: SP-2016-0481C APPLICATION DATE: OCTOBER 14, 2016
APPROVED BY COMMISSION ON UNDER SECTION 112 ON
CHAPTER 25-5 OF THE CITY OF AUSTIN CODE
EXPIRATION DATE (25-5-81, LDC) CASE MANAGER
PROJECT EXPIRATION DATE (ORD.#970905-A) DWP DDZ

Director, DEVELOPMENT SERVICES DEPARTMENT CS, CS-MU-CO,
RELEASED FOR GENERAL COMPLIANCE: [Signature] ZONING PERMITS DIVISION
Rev. 1 Correction 1
Rev. 2 Correction 2
Rev. 3 Correction 3

Final plan must be recorded by the Project Expiration Date, if applicable. Subsequent Site Plans which do not comply with the Code current at the time of filing, and all required Building Permits and/or a notice of construction if a Building permit is not required, must also be approved prior to the Project Expiration Date.

SHEET NO. 15 OF 31