

2003 Melridge (in Barton Springs Zone) - 08 Jul 2019



No j-hook in silt fence to extend up driveway. Insufficient controls on steep slope. Sediment has overtopped mulch sock.



Holes in silt fence.

08 Jul 2019



809 Azie Morton - No erosion controls.



1113 Azie Morton (in the Barton Springs Zone) - Insufficient controls on steep slope.